



SUSTAINABLY DEVELOPING THE OUTBACK

PUBLIC NOTICE

Hot Water Issue – Birdsville

Diamantina Shire Council wishes to advise community members and visitors that due to an issue with the pumps at the water tower last night, the water to town is running hotter than normal the pumps are back up and running, although will take some time for the water to cool.

Council is currently working to implement a resolution to this issue as quickly as possible. We will be cleaning out the heat exchanger later in the night tonight to help with the cooling of the water also.

For residents to keep a steady supply of cool water, we suggest that hot water systems be turned off, which will allow for the bore water flowing into them to cool down and be used for general purposes.

We apologise for the inconvenience and we are working on getting the new system installed and running as soon as possible and this issue will be fixed as soon as possible.

For more information, please contact Jodie Girdler on 4746 1202.

per 

Julianne Meier
CHIEF EXECUTIVE OFFICER

25.02.2025

ABN: 87 774 161 836